



DIARIO DE CALIDAD DE GAS

Calidad de Gas: M-VCBGN010-TH01

Marzo 2026

Descripción: Pto. de Calidad C.F.E. CT Tula T.H.

Perfil de Precisión: Standard Precision

Perfil de Unidad: Internal Storage

| Día | COMPOSICIÓN EN % VOLUMEN | | | | | | | | | | | | | | | Poder Calorífico | Poder Calorífico | Licuable | G.E. |
|-------------------|--------------------------|-------|-------|-------|-------|-------|-------|--------|-------|-------|-------|-----|-------|-------|--------|------------------|------------------|----------|-------|
| | %C1 | %C2 | %C3 | %nC4 | %iC4 | %nC5 | %iC5 | %neoC5 | %C6 | %C7 | %C8 | %C9 | N2 | CO2 | CO2+N2 | BTU(60)/CF | KJoule/m3 | BBL/MMPC | |
| 01/03/26 09:00:00 | 96.09 | 1.642 | 0.076 | 0.008 | 0.012 | 0.002 | 0.003 | | 0.001 | 0.001 | 0.001 | 0 | 1.677 | 0.488 | 2.164 | 1006.806 | 37,499.096 | 0.7 | 0.576 |
| 02/03/26 09:00:00 | 96.142 | 1.62 | 0.071 | 0.008 | 0.011 | 0.002 | 0.003 | | 0.001 | 0.001 | 0.001 | 0 | 1.683 | 0.459 | 2.141 | 1006.742 | 37,496.712 | 0.65 | 0.575 |
| 03/03/26 09:00:00 | 96.09 | 1.665 | 0.075 | 0.009 | 0.012 | 0.002 | 0.003 | | 0.001 | 0.001 | 0.001 | 0 | 1.67 | 0.471 | 2.14 | 1007.244 | 37,515.409 | 0.701 | 0.576 |
| 04/03/26 09:00:00 | 96.121 | 1.662 | 0.073 | 0.009 | 0.012 | 0.002 | 0.003 | | 0.001 | 0.001 | 0.001 | 0 | 1.645 | 0.47 | 2.115 | 1007.453 | 37,523.194 | 0.69 | 0.575 |
| 05/03/26 09:00:00 | 96.214 | 1.5 | 0.066 | 0.008 | 0.01 | 0.002 | 0.003 | | 0.001 | 0.001 | 0 | 0 | 1.794 | 0.401 | 2.196 | 1005.159 | 37,437.752 | 0.609 | 0.574 |
| 06/03/26 09:00:00 | 96.25 | 1.461 | 0.06 | 0.006 | 0.008 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.833 | 0.376 | 2.21 | 1004.483 | 37,412.574 | 0.532 | 0.574 |
| 07/03/26 09:00:00 | 96.11 | 1.512 | 0.062 | 0.006 | 0.007 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.978 | 0.319 | 2.297 | 1003.976 | 37,393.691 | 0.533 | 0.574 |
| 08/03/26 09:00:00 | 96.156 | 1.535 | 0.068 | 0.006 | 0.008 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.882 | 0.339 | 2.221 | 1005.055 | 37,433.879 | 0.582 | 0.574 |
| 09/03/26 09:00:00 | 96.231 | 1.534 | 0.068 | 0.007 | 0.008 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.768 | 0.378 | 2.146 | 1005.838 | 37,463.042 | 0.589 | 0.574 |
| 10/03/26 09:00:00 | 96.135 | 1.581 | 0.071 | 0.007 | 0.008 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.847 | 0.346 | 2.193 | 1005.764 | 37,460.286 | 0.607 | 0.574 |
| 11/03/26 09:00:00 | 96.051 | 1.622 | 0.073 | 0.007 | 0.007 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.91 | 0.325 | 2.235 | 1005.643 | 37,455.779 | 0.611 | 0.575 |
| 12/03/26 09:00:00 | 96.067 | 1.626 | 0.073 | 0.007 | 0.007 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.867 | 0.348 | 2.215 | 1005.882 | 37,464.681 | 0.612 | 0.575 |
| 13/03/26 09:00:00 | 96.146 | 1.597 | 0.071 | 0.007 | 0.007 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.807 | 0.36 | 2.167 | 1006.122 | 37,473.620 | 0.599 | 0.575 |
| 14/03/26 09:00:00 | 96.155 | 1.583 | 0.067 | 0.007 | 0.008 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.768 | 0.406 | 2.175 | 1005.927 | 37,466.357 | 0.589 | 0.575 |
| Promedios | 96.14 | 1.581 | 0.07 | 0.007 | 0.009 | 0.001 | 0.002 | 0 | 0 | 0.001 | 0 | 0 | 1.795 | 0.392 | 2.187 | 1005.864 | 37464.005 | 0.615 | 0.575 |



DIARIO DE CALIDAD DE GAS

Calidad de Gas: M-VCBGN010-TH01

Marzo 2026

Descripción: Pto. de Calidad C.F.E. CT Tula T.H.

Perfil de Precisión: Standard Precision

Perfil de Unidad: Internal Storage

| Día | COMPOSICIÓN EN % VOLUMEN | | | | | | | | | | | | | | | Poder Calorífico | Poder Calorífico | Licuable | G.E. |
|-------------------|--------------------------|-------|-------|-------|-------|-------|-------|--------|-------|-------|-------|-------|-------|-------|--------|------------------|------------------|----------|-------|
| | %C1 | %C2 | %C3 | %nC4 | %iC4 | %nC5 | %iC5 | %neoC5 | %C6 | %C7 | %C8 | %C9 | N2 | CO2 | CO2+N2 | BTU(60)/CF | KJoule/m3 | BBL/MMPC | |
| 15/03/26 09:00:00 | 96.275 | 1.523 | 0.07 | 0.007 | 0.01 | 0.001 | 0.003 | | 0 | 0.001 | 0 | 0 | 1.668 | 0.44 | 2.108 | 1006.259 | 37,478.722 | 0.627 | 0.574 |
| 16/03/26 09:00:00 | 96.167 | 1.526 | 0.065 | 0.006 | 0.009 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.832 | 0.389 | 2.221 | 1004.971 | 37,430.750 | 0.57 | 0.575 |
| 17/03/26 09:00:00 | 96.036 | 1.638 | 0.066 | 0.007 | 0.009 | 0.001 | 0.002 | | 0 | 0.001 | 0.001 | 0 | 1.845 | 0.395 | 2.239 | 1005.675 | 37,456.971 | 0.58 | 0.575 |
| 18/03/26 09:00:00 | 95.94 | 1.801 | 0.066 | 0.007 | 0.009 | 0.001 | 0.002 | | 0 | 0.001 | 0.001 | 0 | 1.713 | 0.457 | 2.17 | 1007.708 | 37,532.691 | 0.599 | 0.576 |
| 19/03/26 09:00:00 | 95.886 | 1.923 | 0.063 | 0.008 | 0.01 | 0.001 | 0.003 | | 0 | 0.001 | 0.002 | 0.001 | 1.592 | 0.511 | 2.103 | 1009.352 | 37,593.923 | 0.598 | 0.577 |
| 20/03/26 09:00:00 | 96.104 | 1.614 | 0.063 | 0.006 | 0.009 | 0.001 | 0.002 | | 0 | 0.001 | 0.001 | 0 | 1.758 | 0.44 | 2.198 | 1005.895 | 37,465.165 | 0.566 | 0.575 |
| 21/03/26 09:00:00 | 96.106 | 1.555 | 0.064 | 0.006 | 0.008 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.877 | 0.38 | 2.257 | 1004.762 | 37,422.966 | 0.551 | 0.575 |
| 22/03/26 09:00:00 | 96.01 | 1.628 | 0.063 | 0.005 | 0.008 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.9 | 0.381 | 2.281 | 1005.026 | 37,432.798 | 0.533 | 0.575 |
| 23/03/26 09:00:00 | 95.889 | 1.688 | 0.065 | 0.005 | 0.008 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.977 | 0.364 | 2.341 | 1004.903 | 37,428.217 | 0.544 | 0.576 |
| 24/03/26 09:00:00 | 95.925 | 1.685 | 0.067 | 0.006 | 0.008 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.96 | 0.344 | 2.305 | 1005.306 | 37,443.227 | 0.566 | 0.575 |
| 25/03/26 09:00:00 | 95.966 | 1.663 | 0.068 | 0.006 | 0.009 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.888 | 0.395 | 2.282 | 1005.437 | 37,448.106 | 0.588 | 0.575 |
| 26/03/26 09:00:00 | 95.955 | 1.661 | 0.069 | 0.006 | 0.007 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.951 | 0.346 | 2.297 | 1005.214 | 37,439.801 | 0.573 | 0.575 |
| 27/03/26 09:00:00 | 96.143 | 1.545 | 0.059 | 0.005 | 0.007 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.92 | 0.316 | 2.236 | 1004.777 | 37,423.524 | 0.498 | 0.574 |
| 28/03/26 09:00:00 | 96.151 | 1.566 | 0.067 | 0.007 | 0.009 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.827 | 0.368 | 2.194 | 1005.607 | 37,454.438 | 0.592 | 0.575 |
| 29/03/26 09:00:00 | 96.2 | 1.546 | 0.069 | 0.008 | 0.01 | 0.002 | 0.003 | | 0.001 | 0.001 | 0.001 | 0 | 1.744 | 0.415 | 2.159 | 1005.967 | 37,467.847 | 0.638 | 0.575 |
| 30/03/26 09:00:00 | 96.03 | 1.62 | 0.066 | 0.007 | 0.009 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.883 | 0.38 | 2.263 | 1005.301 | 37,443.041 | 0.584 | 0.575 |
| 31/03/26 09:00:00 | 96.075 | 1.535 | 0.062 | 0.007 | 0.008 | 0.001 | 0.002 | | 0 | 0.001 | 0 | 0 | 1.977 | 0.332 | 2.309 | 1004.076 | 37,397.415 | 0.543 | 0.575 |
| Promedios | 96.05 | 1.63 | 0.065 | 0.006 | 0.009 | 0.001 | 0.002 | 0 | 0 | 0.001 | 0 | 0 | 1.842 | 0.391 | 2.233 | 1005.661 | 37456.447 | 0.574 | 0.575 |